



### Features

Input 240V  $\pm$ 10%, AC, 50/60Hz. Digital Timer 4 digit, solid state, time interval measuring system, 5 ranges from .0001 to 9999 seconds. Accuracy  $\pm$ 0.5% + 1 count. Timer Control Circuits Timer automatically starts when output is initiated and automatically stops when the device under test operates. Test Conditions Normally open contacts (Potential free) / Normally closed contacts (Potential Free). Auto cut-off Cuts off output on operation of device under test. Duty cycle 10 mins ON / 15 mins OFF. Metering Digital LED volt and amp meters. Accuracy:  $\pm$  1%  $\pm$  3 digits. Operation A SET / TEST switch is provided so that the appropriate test current can be set up before the test is actually carried out, and to avoid damage to relay coils by disconnecting the test current after the relay has operated. Construction Sheet metal cabinet powder coated with cover and lifting handles. Accessories 3 core mains cord, Test leads-2 metre long and operating manual.

### Technical Specification

Output	:	Two independently adjustable outputs available simultaneously
AC Current	:	0 – 7.5V at 100A 0 – 10V at 75A 0 – 15V at 50A 0 – 35V at 20A 0 – 75V at 10A 0 – 150V at 5A
AC Voltage	:	0 – 250V at 2A
Metering	:	Digital Ammeter displays current output in 20-100A. Digital Voltmeter displays voltage output up to 300V, 3 digit, 12.5mm LED display

Note: Specifications are subject to change.

### *Tesca Technologies Pvt. Ltd.*

IT-2013, Ramchandrapura Industrial Area, Sitapura Extension,  
Near Bombay Hospital, Vidhani Circle, Jaipur-302022, Rajasthan, India,  
Tel: +91-141-2771791 / 2771792; Email: info@tesca.in, tesca.technologies@gmail.com  
Website: www.tesca.in