



Features

An open pipe system that simulates a domestic installation for drinking water with four different levels is mounted on the panel of the trainer. The levels represent the cellar (drinking water connection level) and three floors. It is possible to simulate a pipe fracture or a pressure drop. During this process the return of contaminated water into the drinking water pipe can be observed.

Specifications

- Simulation of 3 floors and a cellar of a house
- Devices to prevent the return of contaminated water into the drinking water pipe
- Possible simulations: pipe fracture, pressure drop
- Pipe system made of transparent material
- 2 risers with vent
- 6 outlet valves with hose connections
- 3 transparent water tanks
- Pipe separator, backflow preventer and riser vent as safety devices
- Water meter in feed pipe

Technical Specifications

- Backflow preventers
- 1 pipe separator
- 2 riser vents
- 1 flow rate pipe vent with backflow preventer
- 1 flow rate pipe vent without backflow preventer
- 2 sealing plugs
- 2 pipe sections
- 3 Acrylic tanks: 6.5L

Experiments

- Experiments function of various safety devices
- Pipe separator
- Backflow preventer
- Pipe vents
- Prevention of the return of contaminated water back into the drinking water pipe

Requirements

- Water Source & Water Flushing system

Note: Specifications are subject to change.

Tesca Technologies Pvt. Ltd.

IT-2013, Ramchandrapura Industrial Area, Sitapura Extension,
Near Bombay Hospital, Vidhani Circle, Jaipur-302022, Rajasthan, India,
Tel: +91-141-2771791 / 2771792; Email: info@tesca.in, tesca.technologies@gmail.com
Website: www.tescaglobal.com