







## LFC™\_1B Pressure Regulating Valves

### Plug Assembly, V-Port And Dealing With Cavitation:


Closed Position




5% Open Position




12% Open Position



30% Open Position



40% Open Position



As displayed, the LFC™\_1B pressure regulating valve plug assembly and movements.

**Closed Position:** Shows the plug assembly on the body seat in a fully closed valve position.

**5% Open Position:** Shows the plug assembly in a 5% open position. It can clearly be seen that only the top of the V-Port opens up and creates a flow path. This reduces cavitation and helps with fine control at low flow conditions.

**12% Open Position:** Shows the plug assembly in the 12% open position. Now it can be observed how the V-Port moved away from the seat and the openings are increasing proportionally. At this point the top of the V-Ports are now being exposed to the flow path.

**30% Open Position:** Shows the plug assembly in the 30% opened position. Now it can clearly be seen that the full V-Port is creating a larger orifice in the flow path. Up to this point, cavitation needs to be dealt with to increase the life expectancy of the valve. The V-port trim ensures that the seating elements are further apart from each other during low flow allowing the cavitation to take place on noncritical components of the valve.

**40% Open Position:** Shows the plug assembly in the 40% open position. Now it can clearly be seen that the V-Port is completely away from the seat and the flow path is now relatively large. At this point the flow is approaching its medium demand flow rate and the V-Port has little to no function.

### Materials Of Construction:

Part Name	Material Specification
Body - DN50 to DN100	Casting - 431 S/ Steel
Body - DN150 to DN400	Casting - BS3100 Grade A2
Body seat	431 S/ Steel
Flanges	ASTM A105
Plug	431 S/ Steel
V-Port	431 S/ Steel
Trim	431 S/Steel
Piston rod	431 S/Steel
Piston	431 S/ Steel
Plug seat – 0 to 2,5 MPa	Polyurethane
Plug seat - above 2, 5 MPa	UHMWPE
Sleeve (DN150 to DN400)	431 or 304 S/Steel
Cylinder	431 S/ Steel
Cylinder holder	Carbon steel
Seals	Nitrile (Buna)
O-Rings	Nitrile (Buna)
Hose	Single braided

### Low Maintenance Requirement:

All the moving parts of LFC™\_1B pressure control valve are manufactured from stainless steel which increases reliability and durability. The LFC™\_1B pressure control valve requires minimal maintenance, the majority of which, can be conducted with the valve remaining in situ.



## LFC™\_1B Pressure Regulating Valves

### Robust, Reliable and Efficient:

Due to the minimal number of moving parts to effect the fluid control, the number of potential failures are minimized. The valve can only fail for the following reasons:

- 1. Lack of maintenance:** If filters are utilized in the control system, regular cleaning of the filters are required to prevent the valve operation from slowing down and eventually creating a possible hydraulic locking of the valve. This process depends on the condition of the service water being used. The dirtier the water, the shorter the filter maintenance intervals will need to be. A valve seal replacement program should be employed to ensure that the valves plug seals are replaced in accordance with manufacturer's recommendations. As these seals are largely protected the intervals for maintenance on these items can usually be done in terms of years. If these seals fail, the valve will start to bypass pressure from the Pu to the air vent chamber. Valves are equipped with tell-tale breather holes which will immediately indicate seal failure.
- 2. Mechanical fouling:** Should a large object be introduced into the service water piping and reach the valve inlet, such object could create a mechanical jam and prevent the plug from operating.
- 3. Overriding of the control system:** As the valve is hydraulically actuated and controlled, if the control system is isolated from the service water by way of isolation valves in the control system, the valve will be hydraulically locked in position and will be unable to adjust to the inline condition changes.
- 4. Mechanical failure of the main seating arrangement:** In time, the seating arrangement will experience conditions of high velocity across the seating surface during low flow conditions. The high velocity will eventually cause wear on the seating surface and on the plug seating surface. If the valves starts to bypass across its seat, the downstream pressure could increase to the point where the pressure relief valve is activated during low flow conditions.

All of these conditions are easily avoidable and rectifiable through regular maintenance programs and service water quality control and condition monitoring.

### Dimensions:

Unit	Face to face Dimensions:								Height	
	#300		#600		#900		#1500		Centre line to top of valve	
	(mm)	(inch)	(mm)	(inch)	(mm)	(inch)	(mm)	(inch)	(mm)	(inch)
DN50 / 2"	292	11.50	292	11.50	368	14.49	368	14.49		
DN80 / 3"	356	14.02	356	14.02	381	15.00	470	18.50		
DN100 / 4"	432	17.01	432	17.01	457	17.99	546	21.50		
DN150 / 6"	559	22.01	559	22.01	610	24.02	705	27.76		
DN200 / 8"	660	25.98	660	25.98	737	29.02	832	32.76		
DN250 / 10"	787	30.98	787	30.98	838	32.99	991	39.02		
DN300 / 12"	838	32.99	838	32.99	965	37.99	1130	44.49		
DN350 / 14"	889	35.00	889	35.00	1029	40.51	1257	49.49		
DN400 / 16"	991	39.02	991	39.02	1130	44.49	1384	54.49		

### Valve Sizing:

Please consult with Hydromine for clarification of correct sizing for your requirements.

### Design & Manufacturing Standards:

The LFC™\_1B pressure regulating valve has been designed in accordance with various international standards as set out below:

ASME Boilers and pressure vessels design code

ANSI B16.10 ANSI B16.3

ANSI B16.34 ANSI B16.37

ANSI B16.5 ANSI N278.1

Available sizes: DN50 / 2" to DN400 / 16"

Face to face dimensions to ANSI B16.10

Pressure rating: up to 25MPa / 3 626 psi

Available end connections: ANSI B16.5, BS4504, BS10, AS/NZS 4331.1 (ISO 7005-1) DIN, all makes of grooved or ring joint couplings, HMP™ Couplings, HMP™ -TE tapered couplings and other as per clients requirement.