

Order Code : 20213523.17

Name : 17 Primary injection test set



Specifications

Testing especially if the protective gear is connected to the power line via a current transformer it is advisable to carry out primary injection testing

These sets have been designed to enable the users of heavy electrical equipment to carry out such tests as have been described above with a maximum efficiency at minimum cost, providing a convenient of delivering, controlling and measuring a heavy current in a comparatively low voltage low impedance circuit.

Ideal for testing circuit breakers, ammeters with or without current transformers and much other application where a heavy current supply of short duration is required

Current output	Can Vary from 100A to 4000A
Capacity	Can Vary from 300VA to 40.0kVA
Number of Ranges	Can Vary from 1 to 3
Duty	Cycle 5 mins ON and 5 Mins OFF

Note: Specifications are subject to change, Photos shown above are Indicative, Actual Product can Vary.

TESCA TECHNOLOGIES PVT. LTD.

IT-2013, Ramchandrapura Industrial Area, Sitapura Extension, Jaipur-302029, Rajasthan, India.
Ph/ Fax: 91-141-2771791, 2771792; Email: info@tesca.in, tesca.technologies@gmail.com
Website: www.tesca.in